

U.K. Bathing Beach Monitoring - Season 2006

Devon Area Beach and associated freshwater input results



Site Date / time	T. Colif conf. no/100ml	F. Colif conf. no/100ml	F. Strep conf. no/100ml
---------------------	----------------------------	----------------------------	----------------------------

72915015 Westward Ho! Beach

03/05/2006 1300	< 10	< 2	< 2
07/05/2006 1140	< 10	< 2	< 2
16/05/2006 1135	< 10	< 2	< 2
23/05/2006 1530	549	500	9
01/06/2006 1255	< 10	< 2	< 2
08/06/2006 1155	< 10	6	2
18/06/2006 1035	Sample still in analysis		
Sample count:	6	6	6

72910233 Instow Beach

03/05/2006 1215	< 10	4	19
07/05/2006 1115	< 10	2	< 2
16/05/2006 1105	36	4	< 2
23/05/2006 1450	4,410	3,120	462
01/06/2006 1342	154	93	17
08/06/2006 1125	680	654	36
18/06/2006 1055	Sample still in analysis		
Sample count:	6	6	6

73015012 Saunton Sands

03/05/2006 1045	< 10	< 2	< 2
07/05/2006 1025	< 10	< 2	< 2
16/05/2006 1015	< 10	< 2	< 2
23/05/2006 1215	107	58	42
01/06/2006 1520	18	< 2	< 2
08/06/2006 1020	< 10	2	< 2
18/06/2006 1145	Sample still in analysis		
Sample count:	6	6	6

Bathing Water Directive Standards: Apply to confirmed results (conf.) only.

Guideline (G) :

T. Coli (Total Coliforms) not to exceed 500 (4 in 20 allowed)
 F. Coli (Faecal Coliforms) not to exceed 100 (4 in 20 allowed)
 F. Strep (Faecal Streptococci) not to exceed 100 (2 in 20 allowed)

Imperative (I) :

T. Coli (Total Coliforms) not to exceed 10,000 (1 in 20 allowed)
 F. Coli (Faecal Coliforms) not to exceed 2,000 (1 in 20 allowed)

Designated Beach

Non-Designated Beach

Fresh-water Input